

MOBILE USAGE IN SITE

Date Of Incident: February 2010

Location : Delhi

Description of the accident:

The workman while climbing down through the staircase in construction site, he picked his mobile phone to dial some numbers. In the mean while he lost his balance and fell down through the staircase gap to the ground floor. He died on the spot.

No. of persons Injured:

One

Potential Root Cause:

Disturbance like mobile while work.

Unguarded openings in sites.

Failure to follow DBOCWR Rule No.42

Lessons Learnt:

Miss a call or you will miss the life (Only applicable to work spot)

SEED express its deepest condolence and pray the god to look after the families of the young construction worker.



SAFETY AND ENVIRONMENTAL EDUCATION FOR DEVELOPMENT

SEED

For any feedback Mail at: seedforsafety@gmail.com

Accident-008