



## Bangladesh fire Incident



**Date Of Incident: 26.2.10**

**Location : Bangladesh**

### **Description of the accident:**

An electrical short-circuit likely triggered the fire at the Sweater factory in Gazipur town, which killed 21 people. The fire started on the second floor of the factory, trapping scores of workers knitting sweaters for export.

### **No. of persons Injured:**

24 died & over 50 injured in the blaze.

### **Potential Root Cause:**

Electrical short circuit in cable leads to the fire incident.

### **Lessons Learnt:**

Regular checks of aged electrical cables and accessories will reduce the hazards.

Follow up of rules and regulations also reduce such incidents.

### **Photograph:**

**SEED express its deepest condolence and pray the god to look after the families of the died people.**



*SAFETY AND ENVIRONMENTAL EDUCATION FOR DEVELOPMENT*  
**SEED**

**For any feedback Mail at: [seedforsafety@gmail.com](mailto:seedforsafety@gmail.com)**

Accident-010

