

COMPRESSED GASES STORAGE SAFETY AUDIT

S.NO	OBSERAVTION/CHECK	CONDITION	REMARKS
1	Whether cylinders are stored in upright positions and immobilized by chains		
2	Are cylinders stored away from highly flammable substances and electrical connections..		
3	Segregation Of Oxygen and other flammable gases.		
4	Check for storage area permanently posted with the names of the gases stored in the cylinders		
5	Whether Workers Move the compresed gases in hand trolley		
6	Usage of proper tool for closing and opening of valves.		
7	Whether the empty and full cylinders are stored seperately.		

Other observation if any:

DATE:

AUDITED BY

